

## **ELECTRICITY SAFETY ACT 1998**

### **SECTION 63(1)**

#### **PROHIBITION OF SUPPLY OF ELECTRICAL EQUIPMENT**

I, Paul Fearon, the Director of Energy Safety, under section 63(1) of the *Electricity Safety Act 1998* prohibit the supply of the electrical equipment specified in this notice effective 3 July 2019.

##### **Prohibited Electrical Equipment**

The supply of all Compact RCBOs is prohibited unless the brand and model of RCBO passes the additional testing requirements and is listed on the Energy Safe Victoria website as having complied with the additional verification requirements.

##### **Definitions**

In this notice:

- (a) **additional testing requirements** means the test requirements set out in the Energy Safe Victoria document entitled 'RCBO prohibition - Additional testing and verification requirements for RCBOs' dated 1 July 2019;
- (b) **additional verification requirements** means the verification requirements set out in the Energy Safe Victoria document entitled 'RCBO prohibition - Additional testing and verification requirements for RCBOs' dated 1 July 2019;
- (c) **AS/NZS 4417.2** means AS/NZS 4417.2, Australian/New Zealand Standard 'Regulatory compliance mark for electrical and electronic equipment Part 2: Specific requirements for particular regulatory requirements', as published or amended from time to time;
- (d) **Compact RCBO** means a DIN Rail mountable RCD with integral overcurrent protection that either—
  - (a) meets both of the following criteria, namely:
    - (i) it is less than 110 mm in length (excluding any external clips);

##### **AND**

- (ii) it has a rated short circuit breaking capacity of less than 10 kilo amps;

##### **OR**

- (b) is marked or marketed as being for household or residential use;
- (e) **Energy Safe Victoria** means Energy Safe Victoria established under the *Energy Safe Victoria Act 2005*;
- (f) **Energy Safe Victoria website** means the internet website with the internet address [www.esv.vic.gov.au](http://www.esv.vic.gov.au);
- (g) **RCD** has the same meaning as 'residual current device' in Annex B to AS/NZS 4417.2.

##### **Expiry**

This prohibition expires on 30 June 2020 unless revoked earlier.  
Dated 1 July 2019

PAUL FEARON  
Director of Energy Safety