

# Licensed Electrician's Practical (LEP) Assessment Marking Guide

Sample Paper July 2026

OFFICIAL

## Question 1 – Meter Panel and Switchboard Wiring

The installation is a 3 Phase air-conditioned school, situated at 55 Blyth Road, Williamstown. All final sub-circuits must be RCD protected.

The following equipment is to be installed at the main switchboard:

- 1 – 3Φ 15kW air-conditioner
- 1 – 1Φ 5.6kW oven
- 1 – 1Φ 15A socket outlet
- 38 – 1Φ 25W luminaires, installed over two circuits

The following equipment is to be installed from the distribution board and controlled by an isolator:

- 1 – 1Φ 2.6kW storage water heater
- 5 – 1Φ 10A double socket outlets installed over two circuits
- 10 – 1Φ 12W LED downlights installed on a single circuit

Table C2 Column 3

Circuits	Load Group	Calculations	MD		
			Red	White	Blue
1 – 3Φ 15kW air-conditioner	(c) (i)	Full connected load of first appliance + 75% FLC of remainder $15000/(400/\sqrt{3}) = 21.65A$ <b>(21.65x0.75 for red phase)</b>	16.24A	21.65A	21.65A
1 – 1Φ 5.6kW oven	(c) (i)	Full connected load of first appliance + 75% FLC of remainder $5600/230 = 24.35A$	24.35A		
1 – 1Φ 15A socket outlet	(b) (iii)	Full current rating of highest rated socket outlet + 75% of FLC of remainder <b>= 15A</b>		15A	
38 – 1Φ 25W luminaires	(a)	Full connected load $(38x25)/230 = 4.13A$		4.13A	

Equipment 1Φ Distribution Board					
Circuits	Load Group	Calculations	MD		
			Red	White	Blue
1 – 1Φ 2.6kW storage water heater	(g)	Full-load current $2600/230 = 11.3A$			11.3A
5 – 1Φ 10A double socket outlets	(b) (ii)	1000W for first + 100W for each additional $(1000 + (9 \times 100))/230 = 8.26A$			8.26A
10 – 1Φ 12W LED downlights	(a)	Full Connected Load $(10 \times 12)/230 = 0.52A$			0.52A
Distribution Board MD					20.08A
Total Installation MD			40.59A	40.78A	41.73A

AS/NZS 3008.1.1:2025

Consumer's Mains	Table 3.12	Column 9 (O/H) or 17 (U/G)
Sub-main	Table 3.9	Column 9
Three phase load	Table 3.12	Column 9
Single phase loads	Table 3.15	Column 9

Maximum Demand of the Installation	Current Rating of the Main Switch	Size of the Consumer's Mains Cable		Size of the Main Earth Conductor	
		O/head	U/G	O/head	U/G
41.73A	50A	16mm <sup>2</sup>	10mm <sup>2</sup>	6mm <sup>2</sup>	4mm <sup>2</sup>

Maximum Demand of the Distribution Board	Current Rating of the Distribution Board Sub-main Circuit Protection	Size of the Sub-main Cable
20.08A	25A	4mm <sup>2</sup>

Location	Description	Circuit Loading (Table C9)	Circuit Breaker Rating	Cable Size	AS/NZS 3008
Main Board	1 - 3Φ 15kW air conditioner	21.65A	25A	4mm <sup>2</sup>	T3.12 C9
Main Board	1 - 1Φ 5.6kW oven	24.34	25A	4mm <sup>2</sup>	T3.15 C9
Main Board	1 - 1Φ 15A socket outlet	15A	16/20A	2.5mm <sup>2</sup>	T3.15 C9
Main Board	19 - 1Φ 25W luminaires	9.5/2.07A	10A	1.5mm <sup>2</sup>	T3.15 C9
Main Board	19 - 1Φ 25W luminaires	9.5/2.07A	10A	1.5mm <sup>2</sup>	T3.15 C9
Distribution Board	1 - 1Φ 2.6kW storage water heater	11.3A	16A	2.5mm <sup>2</sup>	T3.15 C9
Distribution Board	2 - 1Φ 10A double socket outlets	4A	16/20A	2.5mm <sup>2</sup>	T3.15 C9
Distribution Board	3 - 1Φ 10A double socket outlets	6A	16/20A	2.5mm <sup>2</sup>	T3.15 C9
Distribution Board	10 – 1Φ 12W LED downlights	5/0.52A	10A	1.5mm <sup>2</sup>	T3.15 C9

[Question 1 = 35 marks]

### Question 2.8 – Testing of Operation of RCDs

Answer: No

Wiring Rules Clause Number: 2.6.2.4 (a) (ii)

[1 mark]

### Question 3.2 – MEN System

- (a) An MEN link and earth electrode must be installed at the distribution board.
- (b) The In an active to earth fault, current flows through the protective earth to the MEN link and then through the sub-main neutral
- (b) A touch voltage between accessible earthed conductive parts.
- (d) Report the fault to the supply company.

[2 + 2 + 2 + 2 = 8 marks]